



HIMACHAL PRADESH STATE ELECTRICITY BOARD LTD

"A State Government Undertaking"

Registered Office

Vidyut Bhawan, HPSEBL, Shimla-171004 (H.P)

Number (CIN)

U40109HP2009SGC031255

GST No.:

HPSEBL 02 AACCH4894EHZB

Telephone Number

0177-2803600, 2801675 (Office), 2658984 (Fax)

Website address

www.hpseb.com

Email

cmd@hpseb.in&directorfa@hpseb.in

Sales Circular No. 3 /2021

No. HPSEBL/CE(Comm.)S-4/Vol- IV/2020-21/4879-15212

Dated: 06-03-2021

To

1. The Chief Engineer (Op), South/Central/North Zone, HPSEBL, Shimla/Mandi/Dharamshala, Chief Engineer (ES), HPSEBL, Hamirpur, CE(SO)/CE(SP), Shimla-4
2. All the Dy. CEs/SEs, (Op) Circle, HPSEBL & Dy. CEs/SEs, ES, Circle HPSEBL.
3. All the Addl.SEs/Sr. EEs, (Op) EDs, HPSEBL & Addl.SEs/Sr. EEs, ES Division, HPSEBL.

Sub: Regarding Solid Tapping of HV/EHV Lines.

Sir,

Please refer to this office letter No. HPSEB/CE(Comm.)LS-General/2011-89-408 dated 05.04.2011 regarding Guidelines for making Power Commitments and Sanction of load under HPSEB Ltd. vide which under Sr. No. 2.1.2.3 following directions were issued:

"Solid tapping of the HV/EHV lines should not be allowed. The proper control and protection switchgear at Toff points in case of the consumers eligible for joint feeder may be provisioned in order to avoid interruption to other part of the HT/EHT lines in case of breakdown on Toff points onwards. This is also required in order to comply with direction of the HPERC, the reliability indices as per Standard of Performance Regulations and to implement SCADA System for remote control and line load flows monitoring".

Further, Sub-Regulation-6 of Regulation 44 of Central Electricity Authority (CEA) Regulations of Measures relating to Safety and Electric Supply 2010 provides as under:

"There shall not be tapping of another transmission line from the main line for 66 kV and above class of lines."

It has been observed by competent authority that solid tapping of HV/EHV lines are still in practice in spite of above directions.

In view of above it has been approved by the Competent Authority that there shall not be any Solid Tapping for 66 kV and above class of line for release of electric connections to the consumer please.

The above instructions may please be followed in letter and spirit.

Yr. Secy HPSEBL, Shimla-4

Yr. Secy (ES)

Yr. Secy (IT)

Yr. Secy (O)


Per *Peamish*
09/3/21

AEIT

[Signature]
Chief Engineer (Comm.),
HPSEB Ltd., Shimla-4.

Copy for information and necessary action is forwarded to:

1. The Director (Energy), Kangana Dhar, New Shimla-171009.
2. The CEO (HIMURJA), SDA Complex, Kasumpti, Shimla-171009
3. The Chief Electrical Inspector, HP Govt., Block No. 29, SDA Complex, Kasumpti, Shimla-9.
4. The Executive Director (Pers.), HPSEBL, Vidyut Bhawan, Shimla-4.
5. The Chief Account Officer, F&A Wing, HPSEBL, Vidyut, Bhawan, Shimla-4.
6. The Resident Account Officer, HPSEBL, Shimla-4.
7. The Secretary, Forum for Redressal of Grievances of HPSEBL, Kasumpti, Shimla-9.
8. The Dy. Secretary (Law), HPSEBL, Shimla-4.
9. The SE (Enf. & EA)/SE (Tariff & SERC) in this office.
- ✓ 10. The SE(IT) in this office to upload the same in the HPSEBL official Website.
11. The Dy. Secy.-cum-PS/Sr. PS to MD/Directors for kind information to MD/Directors.
12. Guard File.


Chief Engineer (Comm.),
HPSEB Ltd., Shimla-4.

SE(IT)