

HIMACHAL PRADESH STATE ELECTRICITY BOARD

Sales Circular No 10/2009

Subject:- Sanction of Load - Amendment in Sales Manual Instruction No.

(a)

Following amendments in the existing provisions of the Instruction No 10 of the Sales Manual Part-1 are hereby made to be applicable with immediate effect.

Designation	D.O.P. for sanction of load	Standard Supply Voltage
Engineer Incharge of Operation Sub-division (AE, AEE, Ex Engg).	< = 50 kW	1 ph. 0.230KV or 3ph. 0.415 KV / 2.2 KV
Sr Ex. Engg/Addl.S.E. Incharge of Operation Division.	> 50 kW to < =100 kW	11 KV or 15 KV or 22 KV
S.E./Dy C.E. Incharge of the Operation Circle	> 100 kW to < = 500 kW	11 KV or 15 KV or 22 KV
Chief Engineer(op)	> 500 kW to < = 2000 kW	11KV or 15KV or 22KV
Board Level Committee	>2000 kW and above All electric furnace(s) load of 100 kW and above. All loads containing steel rolling mills and re-rolling mills	33 KV or 66 KV or 132 KV or 220 KV

Note:

In case of extension of load, the above limits shall apply for total load i.e. sanctioned existing load including additional load. The competent authorities to sanction extension of load in such cases shall be same as for the total connected load after inclusion of additional load.

By order of the Board,


Chief Engineer (Comm),
HPSEB, Vidyut Bhawan,
Shimla-171004.

continued -2

NO. HPSEB CE (COMM)/S-4/08-09- 15783-16002
Copy for information and necessary action is forwarded to :-

Dated:- 2-1-2009

- 1 All the Chief Engineer's(OP) Wing in the HPSEB.
- 2 All the Dy. Chief Engineer's/Superintending Engineer's Under Operation Wings.
- 3 All the Addl. Superintending Engineer's/Sr. Executive Engineer's Under operation wings.
- 4 All the Executive Engineer's /Asstt .Executive Engineer's/ Assistant Engineer under Operation wings.
- 5 The Secretary, HPSEB, Shimla-171004.
- 6 The Chief Accounts Officer, HPSEB, Shimla-171004.
- 7 The Resident Audit Officer, HPSEB, Shimla-171004.
- 8 The Director (En f. & EA)/Director (Tariff & SERC), in this office.
- 9 The Sr. Spl. Private Secretary cum Addl. Secretary to the Chairman & Sr. Private Secretaries to the Members of the Board, HPSEB, Shimla-171004.


Chief Engineer (Comm),
HPSEB, Vidyut Bhawan,
Shimla-171004.

Save Energy for the Benefit of Self & Nation
HIMACHAL PRADESH STATE ELECTRICITY BOARD LIMITED
 (A State Govt. Undertaking)

Sales Circular No.: 10/2013

No. HPSEB Ltd/CE(Comm.)/ S4/2013-14-

863-1182

Dated: 09/04/2013

To

- 1) The Chief Engineer(Op), South, HPSEBL, Shimla-4.
- 2) The Chief Engineer(Op), CZ, HPSEBL, Mandi.
- 3) The Chief Engineer(Op), North, HPSEBL, Dharamshala.
- 4) All the Dy. CE/S.E.s Operation Circle in HPSEBL.
- 5) All the Addl. S.E./ Sr. Executive Engineers, Operation Electrical Divisions in HPSEB.
- 6) All AEEs/AEs Operation Sub-Divisions in HPSEBL.

Subject: - Delegation of Powers for issuance of NOC for installation of Standby Diesel Generating Sets/FOG(s) and guidelines thereof

Sir,

The competent Authority of HPSEBL has approved the delegation of Power for issuance of NOC for Installation of Diesel Generation Sets/FOG(s) as Standby Source as under:-

Sr. No.	Capacity of DG Set(s)	Competent Authority/NOC Issuing Authority
1	Up to 100 kVA	Sr. Xen/Addl. SE
2	100 kVA to 500 kVA	SE(s)/Dy. CE
3	500 kVA to 2 MVA	CE(Op)
4	Greater than 2 MVA	Board level Committee

The NOC(s) for Standby source only shall be issued for the purpose of safeguarding the HPSEBL system due to backflow of power from DG Sets to avoid loss to system and life. Interlocking arrangement alongwith DG set control through 4-pole circuit breaker to ensure safeguard against switching on of D. G. set(s) supply without disconnecting HPSEB Ltd supply shall be provided. However, the synchronization arrangement is not allowed.

The approval of installation of DG Sets has to be obtained by the consumer from Chief Electrical Inspector, Shimla(H.P.). It may be ensured at the time of inspection of interlocking arrangement that the consumer has obtained the approval of Chief Electrical Inspector. In case the approval has not been obtained, the interlocking arrangement shall not be approved and the same may brought to notice of Chief Electrical Inspector and at the same time the consumer may be intimated about disconnection of supply as per clause No. 7.1(g) of HP Electricity Supply code, 2009 to prevent loss of human or animal life or injury to a human being or any animal or damage to property

In case of Captive DG sets the consumer shall apply through the respective Sub-Division of HPSEBL and the same shall be dealt in the office of CE(Comm), HPSEBL as required under Electricity Act, 2003.

The format along with Guidelines for issuance of NOC by the above authorities has also been approved by the competent authority and is enclosed for Standby source. The guidelines may be strictly followed in letter & spirit. Any deviation will be the personal responsibility of the concerned please.

All the instructions pertaining to above issued earlier and included in the Sales Manual stand amended to the extent wherever not in line with the above amendment. The instructions will come into force with immediate effect.

D.A.:- As Above

Yours faithfully,

Chief Engineer (Comm.)
 HPSEB Ltd, Vidyut Bhawan,
 Shimla-171004

Copy for information and necessary action is forwarded to:-

1. The Principal Secretary(MPP & Power)), H.P. Govt., Shimla-1.
1. The Secretary, HPERC, Keonthal Commercial Complex, Khalini, Shimla-2.
2. The Chief Electrical Inspector, H.P. Govt., Block No. 29, SDA Complex, Kasumpti, Shimla-9.
3. The Chief Engineer(ES), HPSEBL, Hamirpur.
4. The Director of Industries, H.P. Govt., Shimla-1.
5. The Executive Director(Pers), HPSEB Ltd., Vidyut Bhawan, Shimla-4.
6. The Chief Accounts Officer, F&A Wing, HPSEB Ltd, Vidyut Bhawan, Shimla-4.
7. The Resident Audit Officer, HPSEB Ltd., Shimla-4.
8. The Special Secretary(law), HPSEBL, Shimla-1.
9. The Addl. Secy-Cum-PS/ Sr. PS to CMD/ Directors for the kind information of CMD/ Directors.
10. The Superintending Engineer (IT), along with copy of Guidelines to upload the Guidelines in the HPSEBL official website.
11. The Guard File

Chief Engineer (Comm.)