



HIMACHAL PRADESH STATE ELECTRICITY BOARD LIMITED

(A STATE GOVERNMENT UNDERTAKING)

REGD. OFFICE: VIDYUT BHAWAN, HPSEBL, SHIMLA-4 (H.P.)

CIN: U40109HP2009SGC031255, GST NO: 02AACCH4894EHZB

**PHONE NO. : 0177-2656624 (OFFICE)
2803315 (FAX)**

**Website: www.hpseb.in Email:
cecommhpsebl@gmail.com**

No. : HPSEBL/CE(Comm.)/SERC-31/2024-25- 408406

Dated: 24-05-2024

To

**The Executive Director (Tech.),
HPERC, Vidyut Aayog Bhawan,
Block No. 37, SDA Complex,
Kasumpti Shimla -171009**

**Sub:- Standards of Performance (SOP) reporting under HPERC
(Distribution Performance Standard) Regulations, 2010 -
Submission of SAIDI, SAIFI and CAIDI, CAIFI return for FY 2023-
24 (Qtr.-3 & Qtr.-4).**

Sir,

The Circle wise Reliability indices (SAIDI, SAIFI, CAIDI and CAIFI) for the FY2023-24 (Qtr.-3 & Qtr.-4) of the HPSEBL is enclosed herewith for information please.

DA.: As Above.

Yours faithfully,

**Chief Engineer (Commercial),
HPSEBL, Vidyut Bhawan,
Shimla -171004.**

Copy to

1. The Electricity Ombudsman, Sharma Sadan, Behind Keonthal Commercial Complex, Khalini, Shimla-2 for kind information please.
2. The Superintending Engineer(IT) for uploading the Reliability Indices on the website of HPSEBL.

DA.: As Above

Signed by Anup Ram

**Date: 24-05-2024 10:44:07
Chief Engineer (Commercial),
HPSEBL, Vidyut Bhawan,
Shimla -171004.**

Reliability Indices (SAIDI, SAIFI, CAIDI, CAIFI), HPSEBL, FY23-24 3rd Quarter Rural

[illegible]

Reliability Indices (SAIDI, SAIFI, CAIDI, CAIFI), HPSEBL, FY23-24 3rd Quarter urban

Sr.No.	Name of Circle	Total Consumer	Interrupted Consumer	Duration of sustained	Total Number of	$\Sigma(R_i * Ni)$	No*Ni	SAIDI	SAIFI	CAIDI	CAIFI
1	3	4	5	6	7	8	9	10	11	12	13
	Nahan	36959	36959	2760	159	10421332	538370	282	14.567	19.35719	14.5667
	Solan	80296	80296	19823	729	34813606	1143677	434	14.243	30.44007	14.2433
	Shimla	109609	50946	7052	411	13188366	870469	120	7.9416	15.15087	17.0862
	Rohru	15529	13507	113	23	259764	114108	17	7.3481	2.276475	8.44806
	Rampur	8676	7929	93	4	86589	11738	10	1.3529	7.37681	1.48039
	Dalhousie	26591	12223	1213	69	2606367	151155	98	5.6844	17.24301	12.3664
	kangra	83208	32446	2430	292	1947876	247728	23	2.9772	7.862963	7.63501
	una	31904	4546	929	33	538153	21431	17	0.6717	25.11096	4.7146
	Hamirpur	39429	39429	7861	278	28934149	2381930	734	60.41	12.14735	60.4101
	Mandi	42931	38934	10242	177	171470192	4049230	3994	94.319	42.34637	104.002
	Bilaspur	45148	37281	8534	425	34404475	2064047	762	45.717	16.66846	55.3646
	Kullu	34828	20039	676	55	2066071	223371	59	6.4135	9.249504	11.1468
		555108	374535	61726	2655	300736940	11817254	542	21.288	25.44897	31.5518
Average SAIDI		542							Minutes		
Average SAIFI		21.29									
Average CAIDI		25							Minutes		
Average CAIFI		31.55180157									

52

[illegible]

Reliability Indices (SAIDI, SAIFI, CAIDI, CAIFI), HPSEBL, FY23-24 4thQuarter Rural

[illegible]

Reliability Indices (SAIDI, SAIFI, CAIDI, CAIFI), HPSEBL, FY23-24 4thQuarter Urban

[illegible]

Reliability Indices (SAIDI, SAIFI, CAIDI, CAIFI), HPSEBL, FY23-24 4th Quarter

[illegible]